



Smart-UPS DP 10000 XL

Status of Smart-UPS DP 10000 XL named UPS_SERV

Describes UPS status

On, Bad Battery, No Alarms Present

UPS: Batteries need immediate replacement.

Serial communication has been established.

UPS is on.

UPS: External battery pack communications lost.

Reason For Last Transfer To Battery: Detection of low utility voltage.
Internal Temperature: 025.0 Degrees Celsius

Describes utility power status

Input Voltage: 228.0 VAC

Input Frequency: 49.90 Hz

Maximum Line Voltage: 228.0 VAC

Minimum Line Voltage: 226.0 VAC

Describes output power status

Output Voltage: 229.0 VAC

Output Frequency: 49.90 Hz

Load Power: 024.0 % Watts

Load Current: 11.90 Amps

Describes battery status

Battery Capacity: 100.0 %

Runtime Remaining: 0038 Minutes

Battery Voltage: 438.0 VDC

Number of Batteries: 001

Number of Bad Batteries: 001

Self-Test Result: Failed

Self-Test Date: 05/12/2016

Calibration Result: Passed

Calibration Date: 04/06/2016

About UPS

Model: Smart-UPS DP 10000 XL

Firmware Revision: 311.5.I

Manufacture Date: 11/15/01

Serial Number: GS0146182109